



**Name of Sampler:** Liz Carr  
**Date Collected:** 01/24/2020  
**School Name:** Hanford High School  
**School Code:** 3833  
**School District:** Richland  
**School Address:** 450 Hanford Street , Richland WA 99354  
**School County:** Benton  
**Number of Samples Collected:** 83  
**School Point of Contact (POC):** Jeff Lettau  
**POC Title:** Director Facilities and Operations  
**POC Email:** Jeffrey.lettau@rsd.edu  
**POC Phone Number:** 509-578-8381  
**Date Samples Sent to Lab:** 01/24/2020  
**Date Samples Received by Lab:** 02/05/2020  
**Shipment Tracking Number:** 8133 8049 7479, 8133 8049 7480, 8133 8049 7490

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
32485	FirstDraw	other	Blank	<1	02/14/2020	
32486	FirstDraw	Tap	Rm 1304 staff lounge	<1	02/14/2020	
32487	FirstDraw	other	Rm 1308 kitchen	4	02/14/2020	Sink 1, right, food prep
32488	FirstDraw	Tap	Rm 1308	1	02/14/2020	Sink left food prep
32489	FirstDraw	other	Rm 1308 kitchen	1	02/14/2020	Same sink as sample 32488
32490	FirstDraw	Tap	Rm 1308 kitchen	1	02/14/2020	Same sink as sample 32487
32491	FirstDraw	PotFiller	Rm 1308 kitchen	9	02/14/2020	
32492	FirstDraw	Tap	Rm 1525 Nurse	<1	02/14/2020	
32493	FirstDraw	Bubbler	Main office hallway	<1	02/14/2020	Low right
32494	FirstDraw	Bubbler	Main office hallway	<1	02/14/2020	Tall left
32495	FirstDraw	Tap	Rm 1511 breakroom	<1	02/14/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
32496	FirstDraw	Tap	Rm 1536 special ed	<1	02/14/2020	Kitchen 1
32497	FirstDraw	Tap	Rm 1536	<1	02/14/2020	Kitchen 2
32498	FirstDraw	Tap	Rm 1536	<1	02/14/2020	Kitchen 3
32499	FirstDraw	Bubbler	Purple NE hallway	<1	02/14/2020	Drinking fountain
32500	FirstDraw	BottleFiller	Purple NE hallway	<1	02/14/2020	
33501	FirstDraw	Tap	Falcons Nest Cafe	<1	02/14/2020	New number sequence
33502	FirstDraw	other	falcons nest cafe	<1	02/14/2020	Same sink as 33501
33503	FirstDraw	Bubbler	Upper level falcon gym	<1	02/14/2020	Drinking fountain right lower
33504	FirstDraw	Bubbler	Upper level falcon gym	<1	02/14/2020	Left
33506	FirstDraw	Bubbler	Upper level falcon gym	<1	02/14/2020	Next to stair 1700c
33507	FirstDraw	Bubbler	Upper level falcon gym	<1	02/14/2020	Left of stair 1700c lower fountain
33507	FirstDraw	Bubbler	Lower level falcon gym	<1	02/14/2020	Low fountain left side
33508	FirstDraw	Bubbler	Lower level falcon gym	<1	02/14/2020	Left side
33509	FirstDraw	Bubbler	Lower level falcon gym	<1	02/14/2020	Right side
33510	FirstDraw	BottleFiller	Lower level falcon gym	<1	02/14/2020	Right side
33511	FirstDraw	Bubbler	Eyrie hallway	<1	02/14/2020	Right lower
33512	FirstDraw	Bubbler	Eyrie hallway	<1	02/14/2020	Left high
33513	FirstDraw	Bubbler	Eyrie Large Gym	<1	02/14/2020	Drinking fountain right
33514	FirstDraw	Bubbler	Eyrie large gym	<1	02/14/2020	Left tall

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
33515	FirstDraw	Bubbler	Modular hallway	<1	02/14/2020	Drinking fountain
33516	FirstDraw	Bubbler	Modular hallway	<1	02/14/2020	Hydration station
33517	FirstDraw	BottleFiller	Modular hallway	<1	02/14/2020	
33518	FirstDraw	Bubbler	Rm 101	<1	02/14/2020	
33519	FirstDraw	Tap	Rm 101	<1	02/14/2020	
33520	FirstDraw	Bubbler	Rm 102	<1	02/14/2020	
33521	FirstDraw	Tap	Rm 102	<1	02/14/2020	
33522	FirstDraw	Bubbler	Rm 103	<1	02/14/2020	
33523	FirstDraw	Tap	Rm 103	1	02/14/2020	
33524	FirstDraw	Bubbler	Rm 104	<1	02/14/2020	
33525	FirstDraw	Tap	Rm 104	<1	02/14/2020	
33526	FirstDraw	Bubbler	Rm 105	<1	02/14/2020	
33527	FirstDraw	Tap	Rm 105	<1	02/14/2020	
33528	FirstDraw	Bubbler	Rm 106	<1	02/14/2020	
33529	FirstDraw	Tap	Rm 106	<1	02/14/2020	
33530	FirstDraw	Bubbler	Rm 107	<1	02/14/2020	
33531	FirstDraw	Tap	Rm 107	1	02/14/2020	
33532	FirstDraw	Bubbler	Rm 108	<1	02/14/2020	
33533	FirstDraw	Tap	Rm 108	<1	02/14/2020	
33534	FirstDraw	Bubbler	Rm 108	<1	02/14/2020	
33535	FirstDraw	Tap	Rm 108	<1	02/14/2020	
33536	FirstDraw	Bubbler	Rm 110	<1	02/14/2020	
33537	FirstDraw	Tap	Rm 110	<1	02/14/2020	
33538	FirstDraw	Bubbler	Rm 111	<1	02/14/2020	
33539	FirstDraw	Tap	Rm 111	<1	02/14/2020	
33540	FirstDraw	Bubbler	Rm 112	<1	02/14/2020	
33541	FirstDraw	Tap	Rm 112	<1	02/14/2020	Lots of cups
33542	FirstDraw	Bubbler	Library main entrance	<1	02/14/2020	Lower right drinking fountain

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
33543	FirstDraw	Bubbler	Library main entrance	<1	02/14/2020	Left high drinking fountain
33544	FirstDraw	Tap	Rm 2401 library staff room	<1	02/14/2020	
33545	FirstDraw	Bubbler	Gold SE hallway	<1	02/14/2020	
33546	FirstDraw	BottleFiller	Gold SE hallway	<1	02/14/2020	
33547	FirstDraw	Tap	Fly Buy Store	<1	02/14/2020	
33548	FirstDraw	Tap	Rm 1302b Fly Store Storage	12	02/14/2020	
33549	FirstDraw	Bubbler	2nd floor Gold SE hallway	<1	02/14/2020	Drinking fountain right low
33550	FirstDraw	Bubbler	2nd floor Gold SE hallway	<1	02/14/2020	Left drinking fountain
33551	FirstDraw	Tap	Rm 2204A staff kitchen	<1	02/14/2020	
33552	FirstDraw	Tap	Rm 2501 home economics	<1	02/14/2020	Sink 1 Named Black
33553	FirstDraw	Tap	Rm 2501	<1	02/14/2020	Sink 2 Gray
33554	FirstDraw	Tap	Rm 2501	<1	02/14/2020	Sink 3 Burgundy
33555	FirstDraw	Tap	Rm 2501	<1	02/14/2020	Sink 4 Brown
33556	FirstDraw	Tap	Rm 2501	<1	02/14/2020	Sink 5 Teal
33557	FirstDraw	Tap	Rm 2501	<1	02/14/2020	Sink 6 Purple
33558	FirstDraw	Tap	Rm 2501	<1	02/14/2020	Sink 7 Blue
33559	FirstDraw	Tap	Rm 2501	<1	02/14/2020	Sink 8 Island
33560	FirstDraw	Bubbler	Purple NE Hallway 2nd floor	<1	02/14/2020	Right low

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
33561	FirstDraw	Bubbler	Purle NE hallway 2nd floor	<1	02/14/2020	
33562	FirstDraw	Bubbler	Auditorium hallway	<1	02/14/2020	Right lower
33563	FirstDraw	Bubbler	Auditorium hallway	<1	02/14/2020	Left tall
33564	FirstDraw	Bubbler	Auditorium hallway next to stairs	<1	02/14/2020	Right low
33565	FirstDraw	Bubbler	Auditorium hallway next to stairs	<1	02/14/2020	Left tall
33566	FirstDraw	Bubbler	Wood shop Hallway	<1	02/14/2020	Right low drinking fountain
33567	FirstDraw	Bubbler	Wood shop hallway	<1	02/14/2020	Left Tall